

Government of Jammu and Kashmir
Office of the Joint Director Fire & Emergency Services
Jammu Range, Jammu

The Principal
Govt. Polytechnic College
Doda

No: JDJF&ES/FP/ 3647

Dated: 11-06-2018

Sub: FIRE SAFETY CERTIFICATE.

Ref: Assistant Director, Fire & Emergency Services Command Doda office Letter No. GB/FP/ADF&ESD/568-69 dated 10.05.2018.

Dear Sir,


The management has installed:-

- (i) 05 Nos. ABC Type First Aid Fire Extinguishers of 06 kg capacity
- (ii) Underground water storage tank of 10000 ltrs. capacity

As such, this office has no objection for running the school. However the management advised to adopt the following fire safety measures in letter and spirit forthwith:-

1. 04 Nos. of Fire buckets each filled with fine sand and water should be provided in the school premises as a fire point.
2. Fire fighting system installed in the School building should be checked periodically. Staff and students should be fully trained in handling/ operating of fire fighting system installed in the School building. The management shall intimate the office of Assistant Director, Fire & Emergency Services Command Doda after each quarter that the fire fighting equipments is functioning.
3. No hazardous material should be allowed to store in the school building.
4. Evacuation drill should be conducted periodically and intimate District Officer after every quarter.
5. The management of the school shall be responsible for evacuation of its students, teachers and employees in case of any fire incident.
6. No addition/alteration should be made by the school management in the existing structure without prior permission from this department. Any deviation found in this regard, the NOC will be treated cancelled.
7. The validity of this communication is till the renewal of affiliation by the respective education authority or board of school education.

Yours Sincerely


Joint Director
Fire & Emergency Services
Jammu Range, Jammu
Jammu Range, Jammu